

# Certificate of Compliance

Certificate Number **20069214-R15431**  
Report Reference **2006 February 14**  
Issue Date **2006 February 14**

Page 1 of 1



*Issued to:* **Hilti, Inc.**  
5400 S 122ND East Ave  
Tulsa, OK 74146 USA


*This is to certify that representative samples of* **Firestop Devices**  
CP643N 50/1.5 in., CP643N 63/2 in., CP643N 90/3 in. and CP643N 110/4 in., CP643N 160/6 in., CP644 200/8 in. and CP644 250/10 in.

*Have been investigated by Underwriters Laboratories Inc.® in accordance with the Standard(s) indicated on this Certificate.*


*Standard(s) for Safety:* **ANSI/UL 1479, CAN/ULC-S115-05**


*Additional Information:* **CP 643N and CP 644 Firestop Collar for use in Through-Penetration Firestop Systems as currently described in the UL Fire Resistance Directory.**

**Only those products bearing the UL Classification Mark should be considered as being covered by UL's Classification and Follow-Up Service.**

The UL Classification Mark includes: UL in a circle symbol:  with the word "CLASSIFIED" (as shown); a control number (may be alphanumeric) assigned by UL; a statement to indicate the extent of UL's evaluation of the product; and, the product category name (product identity) as indicated in the appropriate UL Directory.

**Look for the UL Classification Mark on the product**

Issued by:  
  
**Mona Couloute**  
Underwriters Laboratories Inc.

Reviewed by:  
  
**Christopher Johnson**  
Underwriters Laboratories Inc.